

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by BAHADUR PRASAD (A.D.O.P.)

(Name of Officers with designation) from B.D.O. HANUMANUAN PHED OFFICE

inspected the GYAN PEETHIKA

(Name & Address of the school) on 12-12-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. TC-BU/1/DEC05/1320 dated 08-12-2025

of UP JAL NIGAM (RURAL) BALLIA (PHED Lab) certified that the

GYAN PEETHIKA, BALLIA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR (1).

Signature with Seal: .....

Name : .....

Designation : .....

Name & Address of the Office / Department : .....

To

GYAN PEETHIKA

JEERA BASTI NEAR JANESHWAR

(Name & Address of the Institution)

MISHRA PARK BALLIA (UP)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

  
Signature of authorized officer



# Water Analysis Report



## District Level Water Analysis Laboratory

(An NABL Accredited Laboratory)

Office of Executive Engineer, Khand Karyalya, Opposite SMTD College  
Ballia-277001

URL No.: TC-BUI/DEC25/1328		Date 8/12/2025		No. of Pages: 1	
Customer Details					
Office Name and Address	GYAN PITHIKA SCHOOL, BALLIA				
Ref. Letter No. & Date					
Basic Details of Sample					
District	BALLIA		Block	HANUMANGANJ	
Gram Panchayat	JIRA BASTI		Village	JIRA BASTI	
Habitation	JIRA BASTI		Latitude		
Water Source	RO		Longitude		
Quantity of Sample	1000 ML		Sample Code	BUI/DEC25/1328	
Sample Received Date	3/12/2025		Sampling date	3/12/2025	
Sampling Method Used	IS 17614 (Part 3):2022		S. collected by	IMTIYAZ	
Analysis Start Date	3/12/2025	Analysis Completion date	8/12/2025		
HUMIDITY-69%					
S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
3	pH	6.79	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
4	Turbidity (NTU)	0.78	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
5	Total Dissolved Solids, mg/l	50.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
6	Chloride (as Cl), mg/l	5.99	250	1000	IS 3025 (Part 32): 2019 Argentometric method
7	Total Alkalinity, (as CaCO <sub>3</sub> ) mg/l	24.00	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
8	Total Hardness, (as CaCO <sub>3</sub> ) mg/l	14.00	200	600	IS 3025 (Part 21): 2019 (EDTA method)
9	Calcium (Cl), mg/l	3.20	75	200	IS 3025 (PART40) 2019; EDTA titrimetric method
10	Magnesium mg/l	1.46	30	100	IS 3025 (PART46) 2019; Volumetric method using EDTA
11	Sulphate (as SO <sub>4</sub> ), mg/l	3.21	200	400	APHA 24rd Edition -4500-SO <sub>4</sub> Method E (Turbidimetric Method): 2023
12	Nitrate (as NO <sub>3</sub> ), mg/l	0.71	45	No relaxation	APHA 24rd Edition -4500- NO <sub>3</sub> Method B (UV Screening Method): 2023
13	Fluoride (as F), mg/l	0.02	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method) : 2023
14	Iron (as Fe), mg/l	0.31	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023
15	Color (Hazen unit)	NA	5.0	15	APHA 24rd Edition-2120 Color method B (Platinum cobalt visual compriison):2023
16	Total Arsenic (as As), mg/l	BDL	0.01	No relaxation	APHA 24rd Edition -3500 Method B (Silver Diethyldithiocarbamate Method): 2023
BDL-Below Detection Limit, NA- Not Analysed					
<p><b>Note:</b></p> <ol style="list-style-type: none"> <li>1. This certificate refers only to the particular sample(s) submitted for analysis.</li> <li>2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.</li> <li>3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.</li> <li>4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.</li> <li>5. Parameters above Permissible Limit are written in <b>bold</b>.</li> <li>6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.</li> <li>7. Sample is Not Collected by Lab.</li> </ol>					
 <b>SHUBHANKAR CHAUDHARY</b> (Report prepared by)		 <b>SHIV SHANKAR AGGARWAL</b> (Report Review by)		 <b>ASHUTOSH KUMAR GIRIRAJ</b> (Report Authorized by) U.P. Jhajjar (Rural) Ballia	

\*\*\*\*\*END OF THE ANALYSIS REPORT\*\*\*\*\*